

## BRE Global Ireland

### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F0859

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### DMCFA3000 Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

**Cooper Securite SAS**  
**Parc Européen d'Entreprises II**  
**Rue Beethoven**  
**BP 10184**  
**63204 Riom Cedex**  
**France**

**SC Cooper Industries Romania SRL**  
**Zona Industrială NV.**  
**Str. III, NR 12**  
**Arad**  
**310510**  
**Romania**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-5:2017 + A1:2018 - Heat detectors – Point heat detectors**  
**EN 54-7:2018 - Smoke detectors - Point smoke detectors**  
**EN 54-17:2005 Short Circuit Isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 05 November 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020

Date of Issue: 21 October 2022

Issue number 2

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland****Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F0859****DMCFA3000 Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit isolator****Heat Classifications:**

Category A2S

**Sensitivities:**

Meets the requirements of EN 54-5 and EN 54-7 in the following modes:

Mode 2 - Photoelectric/Heat combined together with an alarm output from temperature alone(Category A2S)

Mode 3 - Heat detector(Category A2S)

**Bases:**

NUG30256      Single contact standard analogue addressable mounting base  
NUG30258      Double contact standard analogue addressable mounting base



P Halligan, Certification Manager,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020

Date of issue: 21 October 2022

Issue number: 2

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)